

REPORT NUMBER: 102816357MID-001
ORIGINAL ISSUE DATE: November 30, 2016
REVISED DATE: N/A

EVALUATION CENTER

Intertek
Verification Center
8431 Murphy Dr
Middleton, WI 53562

RENDERED TO

Michelle Wang
Michelle.wang@terasun.cn
Zhejiang Terasun Air Duct Co., Ltd.
(Maren) Chongren Industrial Clustering Area,
Shengzhou City,
Zhejiang, China

PRODUCT EVALUATED:Terasun Magnesium Board.

EVALUATION PROPERTY: ULC S135-04 standard test method for the determination of combustibility parameters the determination of combustibility parameters of building materials using an oxygen consumption calorimeter (cone calorimeter)

Report for compliance with the applicable requirements in accordance to the National Building Code of Canada for materials used in buildings that are required to be noncombustible.

"This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program."

1 Table of Contents

1	Table of Contents	2
2	Introduction	3
3	Test Samples	3
3.1.	SAMPLE SELECTION	3
3.2.	SAMPLE AND ASSEMBLY DESCRIPTION.....	3
4	Testing and Evaluation Methods	3
4.1.	ULC S135-04	3
4.2.	Deviation from Standard Method.....	4
5	Testing and Evaluation Results	5
5.1.	RESULTS AND OBSERVATIONS.....	5
6	Conclusion	16

2 Introduction

Intertek has conducted testing for Zhejiang Terasun Air Duct Co., Ltd., on Terasun Magnesium Board to evaluate heat and smoke release rates. Testing was conducted following the standard methods of ULC S135-04 Standard Test Method for the Determination of Combustibility Parameters of Building Materials Using an Oxygen Consumption Calorimeter (Cone Calorimeter) in accordance with the National Building Code of Canada for materials used in buildings that are required to be noncombustible. The evaluation began November 29, 2016 and was completed November 29, 2016.

3 Test Samples

3.1. SAMPLE SELECTION

Samples were selected by an Intertek auditor. Samples were received at the Intertek Middleton Evaluation Center on November 15, 2016 in good condition.

3.2. SAMPLE AND ASSEMBLY DESCRIPTION

Sample name: Terasun Magnesium Board.

Sample description: Model: 12mm thickness. Samples were cut to 100 +/- 1 mm by 100 +/- 1 mm dimensions by the client.

Specimens were conditioned to moisture equilibrium (constant mass) at an ambient temperature of $23 \pm 3^{\circ}\text{C}$ and a relative humidity of $50 \pm 5\%$.

4 Testing and Evaluation Methods

4.1. ULC S135-04

The testing was performed in accordance with the ULC S135-04 standard. Specimens in the test are burned in ambient air conditions, while being subjected to a predetermined external heat flux. Testing was done at 50 kW/m^2 with spark ignition.

Collect data for at least 15 minutes.

The total *heat release* per unit area shall be compared for the three specimens. If any of these readings differ by more than 10% from the average of the three readings, then a further set of three specimens shall be tested. In such cases, report the averages for peak heat release rate per unit area, total heat release per unit area, and total smoke extinction area using the set of six readings.

National Building Code of Canada:

Materials used in buildings that are required to be of noncombustible combustible that have been tested in conformance with ULC-S135, "Test for the Determination of Combustibility Parameters of Building Materials Using an Oxygen Consumption Calorimeter (Cone Calorimeter)," at a heat flux of 50 kW/m^2 where:

- The materials' total heat release is not more than 3 MJ/m^2 ,
- the materials' average total smoke extinction area is not more than 1.0 m^2 , and
- the test duration is extended beyond the time stipulated in the referenced standard until it is clear that there is no further release of heat or smoke.

4.2. Deviation from Standard Method

There were no deviations from the standard.

5 Testing and Evaluation Results

5.1. RESULTS AND OBSERVATIONS

Sample description	102816357MID-001 Terasun Mg Board
Material name/ID	102816357MID-001 Terasun Mg Board

Specimen information

E	13.1 MJ/kg	Specimen number	1	Conditioned?	Yes
Thickness	12 mm	Nominal duct flow rate	24 l/s	Temperature	23°C
Initial mass	125.6 g	Edge frame used?	Yes	RH	50%
Surface area	88.4 cm ²	Grid used?	No		
Heat flux	50 kW/m ²	Manufacturer			
Separation	25 mm	Sponsor			
Orientation	Horizontal				

Test

Standard used	ULC S135
Date of test	29/11/2016
Time of test	07:43
Date of report	29/11/2016

Pre-test conditions

Ambient temperature	18.9°C
Ambient pressure	96.811 kPa
Relative humidity	35%

Test times

Time to ignition	0 s
Time to flameout	s
End of test criterion	User entered
End of test time	900 s
(for calculations)	

Apparatus specifications

C-factor	0.04298
Duct diameter	0.114 m
O ₂ delay time	17 s
CO ₂ delay time	17 s
CO delay time	17 s
OD corr. factor	1.0055

Initial conditions

Baseline ambient oxygen	20.786%
Baseline oxygen	20.952%
Baseline carbon dioxide	0.0759%
Mass at sustained flaming	125.6 g

Heat Release Results

THR (0-300)	0.88 MJ/m ²
THR (0-600)	2.40 MJ/m ²
THR (0-1200)	-
Fuel load	0.35 MJ/kg

Test results (between 0 and 900 s)

		Mean	Peak	at time (s)	
Total heat release	5.0 MJ/m ²	Heat release rate (kW/m ²)	5.45	13.15	725
Total oxygen consumed	3.7 g	Effective heat of comb. (MJ/kg)	1.38	77.51	184
Mass lost	31.5 g	Mass loss rate (g/s)	0.035	0.246	109
Average specific MLR	4.33 g/(s·m ²)	Specific extinction area (m ² /kg)	18.58	3237.91	14
Total smoke release	75.0 m ² /m ²	Carbon monoxide yield (kg/kg)	0.0088	7.7142	900
Total smoke production	0.7 m ²	Carbon dioxide yield (kg/kg)	0.16	120.09	309
MAHRE	5.5 kW/m ²				

Test averages

from ignition to ignition plus...	1 min	2 min	3 min	4 min	5 min	6 min	0 s - 905 s	0 s - 905 s
Heat release rate (kW/m ²)	0.70	0.74	1.58	2.15	2.73	3.00	5.47	5.47
Effective heat of comb. (MJ/kg)	0.20	0.20	0.37	0.48	0.57	0.62	1.38	1.38
Mass loss rate (g/s)	0.031	0.032	0.038	0.040	0.043	0.043	0.035	0.035
Specific extinction area (m ² /kg)	15.70	18.36	15.41	13.95	11.79	11.11	18.54	18.54
Carbon monoxide yield (kg/kg)	0.0001	0.0015	0.0025	0.0031	0.0034	0.0038	0.0088	0.0088
Carbon dioxide yield (kg/kg)	0.08	0.09	0.09	0.10	0.11	0.11	0.17	0.17

Smoke results

Total smoke release: non-flaming phase (0 s - 0 s)	0.0 m ² /m ²
Total smoke release: flaming phase (0 s - 900 s)	75.0 m ² /m ²
Total smoke release: whole test (0 s - 900 s)	75.0 m ² /m ²

Sample description 102816357MID-001 Terasun Mg Board
Material name/ID 102816357MID-001 Terasun Mg Board

Specimen information

E	13.1 MJ/kg	Specimen number	2	Conditioned?	Yes
Thickness	12 mm	Nominal duct flow rate	24 l/s	Temperature	23°C
Initial mass	125.9 g	Edge frame used?	Yes	RH	50%
Surface area	88.4 cm ²	Grid used?	No		
Heat flux	50 kW/m ²	Manufacturer			
Separation	25 mm	Sponsor			
Orientation	Horizontal				

Test

Standard used	ULC S135
Date of test	29/11/2016
Time of test	08:05
Date of report	29/11/2016

Pre-test conditions

Ambient temperature	18.6°C
Ambient pressure	96.811 kPa
Relative humidity	35%

Test times

Time to ignition	0 s
Time to flameout	s
End of test criterion	User entered
End of test time	900 s
(for calculations)	

Apparatus specifications

C-factor	0.04298
Duct diameter	0.114 m
O ₂ delay time	17 s
CO ₂ delay time	17 s
CO delay time	17 s
OD corr. factor	1.0055

Initial conditions

Baseline ambient oxygen	20.786%
Baseline oxygen	20.948%
Baseline carbon dioxide	0.0787%
Mass at sustained flaming	125.9 g

Heat Release Results

THR (0-300)	0.56 MJ/m ²
THR (0-600)	0.92 MJ/m ²
THR (0-1200)	-
Fuel load	0.08 MJ/kg

Test results (between 0 and 900 s)

		Mean	Peak	at time (s)	
Total heat release	1.1 MJ/m ²	Heat release rate (kW/m ²)	0.70	6.59	126
Total oxygen consumed	1.2 g	Effective heat of comb. (MJ/kg)	0.18	66.34	330
Mass lost	31.3 g	Mass loss rate (g/s)	0.035	0.285	625
Average specific MLR	4.30 g/(s·m ²)	Specific extinction area (m ² /kg)	21.40	4336.10	523
Total smoke release	81.2 m ² /m ²	Carbon monoxide yield (kg/kg)	0.0085	7.3949	783
Total smoke production	0.7 m ²	Carbon dioxide yield (kg/kg)	0.12	87.35	135
MAHRE	2.0 kW/m ²				

Test averages

from ignition to ignition plus...	1 min	2 min	3 min	4 min	5 min	6 min	0 s - 946 s	0 s - 946 s
Heat release rate (kW/m ²)	0.02	0.64	1.20	1.68	1.64	1.76	0.65	0.65
Effective heat of comb. (MJ/kg)	0.00	0.17	0.29	0.37	0.34	0.37	0.17	0.17
Mass loss rate (g/s)	0.034	0.032	0.037	0.040	0.042	0.042	0.034	0.034
Specific extinction area (m ² /kg)	16.12	22.98	19.28	17.63	16.20	16.03	22.42	22.42
Carbon monoxide yield (kg/kg)	0.0002	0.0020	0.0033	0.0036	0.0039	0.0045	0.0091	0.0091
Carbon dioxide yield (kg/kg)	0.06	0.08	0.09	0.10	0.10	0.10	0.12	0.12

Smoke results

Total smoke release: non-flaming phase (0 s - 0 s)	0.0 m ² /m ²
Total smoke release: flaming phase (0 s - 900 s)	81.2 m ² /m ²
Total smoke release: whole test (0 s - 900 s)	81.2 m ² /m ²

Sample description 102816357MID-001 Terasun Mg Board
Material name/ID 102816357MID-001 Terasun Mg Board

Specimen information

E	13.1 MJ/kg	Specimen number	3	Conditioned?	Yes
Thickness	12 mm	Nominal duct flow rate	24 l/s	Temperature	23°C
Initial mass	125.1 g	Edge frame used?	Yes	RH	50%
Surface area	88.4 cm ²	Grid used?	No		
Heat flux	50 kW/m ²	Manufacturer			
Separation	25 mm	Sponsor			
Orientation	Horizontal				

Test		Pre-test conditions		Test times	
Standard used	ULC S135	Ambient temperature	18.8°C	Time to ignition	not recorded
Date of test	29/11/2016	Ambient pressure	96.821 kPa	Time to flameout	s
Time of test	08:28	Relative humidity	36%	End of test criterion	User entered
Date of report	29/11/2016			End of test time	900 s
				(for calculations)	

Apparatus specifications		Initial conditions		Heat Release Results	
C-factor	0.04298	Baseline ambient oxygen	20.783%	THR (0-300)	0.44 MJ/m ²
Duct diameter	0.114 m	Baseline oxygen	20.952%	THR (0-600)	1.24 MJ/m ²
O ₂ delay time	17 s	Baseline carbon dioxide	0.0741%	THR (0-1200)	-
CO ₂ delay time	17 s	Mass at sustained flaming	no ignition	Fuel load	0.16 MJ/kg
CO delay time	17 s				
OD corr. factor	1.0055				

Test results (between 0 and 900 s)

		Mean	Peak	at time (s)
Total heat release	2.2 MJ/m ²	Heat release rate (kW/m ²)	2.36	7.54
Total oxygen consumed	2.0 g	Effective heat of comb. (MJ/kg)	0.58	78.32
Mass lost	32.2 g	Mass loss rate (g/s)	0.036	0.360
Average specific MLR	4.46 g/(s·m ²)	Specific extinction area (m ² /kg)	-3.28	2086.32
Total smoke release	24.4 m ² /m ²	Carbon monoxide yield (kg/kg)	0.0076	14.9949
Total smoke production	0.2 m ²	Carbon dioxide yield (kg/kg)	0.12	158.40
MAHRE	3.5 kW/m ²			786

Test averages

	between time 0 and... 1 min	2 min	3 min	4 min	5 min	6 min	0 s - 908 s	0 s - 908 s
Heat release rate (kW/m ²)	0.68	0.81	0.89	0.96	1.18	1.31	2.39	2.39
Effective heat of comb. (MJ/kg)	0.26	0.22	0.22	0.21	0.24	0.27	0.60	0.60
Mass loss rate (g/s)	0.023	0.033	0.036	0.041	0.043	0.044	0.035	0.035
Specific extinction area (m ² /kg)	-4.33	-2.36	-3.41	-4.40	-4.72	-4.29	-3.33	-3.33
Carbon monoxide yield (kg/kg)	0.0009	0.0015	0.0026	0.0029	0.0032	0.0034	0.0078	0.0078
Carbon dioxide yield (kg/kg)	0.10	0.08	0.08	0.08	0.08	0.08	0.12	0.12

Smoke results

Total smoke release: whole test (0 s - 900 s) 24.4 m²/m²

Sample description 102816357MID-001 Terasun Mg Board
Material name/ID 102816357MID-001 Terasun Mg Board

Specimen information

E	13.1 MJ/kg	Specimen number	4	Conditioned?	Yes
Thickness	12 mm	Nominal duct flow rate	24 l/s	Temperature	23°C
Initial mass	124.7 g	Edge frame used?	Yes	RH	50%
Surface area	88.4 cm ²	Grid used?	No		
Heat flux	50 kW/m ²	Manufacturer			
Separation	25 mm	Sponsor			
Orientation	Horizontal				

Test		Pre-test conditions		Test times	
Standard used	ULC S135	Ambient temperature	21.3°C	Time to ignition	not recorded
Date of test	29/11/2016	Ambient pressure	97.15 kPa	Time to flameout	s
Time of test	10:24	Relative humidity	32%	End of test criterion	User entered
Date of report	29/11/2016			End of test time	900 s
				(for calculations)	
Apparatus specifications		Initial conditions		Heat Release Results	
C-factor	0.04298	Baseline ambient oxygen	20.771%	THR (0-300)	0.12 MJ/m ²
Duct diameter	0.114 m	Baseline oxygen	20.946%	THR (0-600)	0.43 MJ/m ²
O2 delay time	17 s	Baseline carbon dioxide	0.0756%	THR (0-1200)	-
CO2 delay time	17 s	Mass at sustained flaming	no ignition	Fuel load	0.07 MJ/kg
CO delay time	17 s				
OD corr. factor	1.0055				

Test results (between 0 and 900 s)

		Mean	Peak	at time (s)
Total heat release	1.0 MJ/m ²	Heat release rate (kW/m ²)	0.48	5.50
Total oxygen consumed	1.1 g	Effective heat of comb. (MJ/kg)	0.12	75.33
Mass lost	32.0 g	Mass loss rate (g/s)	0.036	0.416
Average specific MLR	4.33 g/(s·m ²)	Specific extinction area (m ² /kg)	0.15	4527.03
Total smoke release	29.3 m ² /m ²	Carbon monoxide yield (kg/kg)	0.0063	20.1034
Total smoke production	0.3 m ²	Carbon dioxide yield (kg/kg)	0.12	372.46
MAHRE	1.1 kW/m ²			459

Test averages

between time 0 and... 1 min	2 min	3 min	4 min	5 min	6 min		0 s - 903 s	0 s - 903 s
Heat release rate (kW/m ²)	-1.23	-1.31	-1.01	-0.86	-0.82	-0.81	0.48	0.48
Effective heat of comb. (MJ/kg)	-0.33	-0.31	-0.23	-0.18	-0.16	-0.16	0.12	0.12
Mass loss rate (g/s)	0.032	0.037	0.038	0.043	0.044	0.044	0.035	0.035
Specific extinction area (m ² /kg)	-4.83	-1.28	1.04	0.19	-0.34	-0.40	0.14	0.14
Carbon monoxide yield (kg/kg)	0.0008	0.0011	0.0023	0.0025	0.0028	0.0031	0.0063	0.0063
Carbon dioxide yield (kg/kg)	0.08	0.08	0.09	0.09	0.09	0.09	0.12	0.12

Smoke results

Total smoke release: whole test (0 s - 900 s) 29.3 m²/m²

Sample description 102816357MID-001 Terasun Mg Board
Material name/ID 102816357MID-001 Terasun Mg Board

Specimen information

E	13.1 MJ/kg	Specimen number	5	Conditioned?	Yes
Thickness	12 mm	Nominal duct flow rate	24 l/s	Temperature	23°C
Initial mass	126.6 g	Edge frame used?	Yes	RH	50%
Surface area	88.4 cm ²	Grid used?	No		
Heat flux	50 kW/m ²	Manufacturer			
Separation	25 mm	Sponsor			
Orientation	Horizontal				

Test

Standard used	ULC S135
Date of test	29/11/2016
Time of test	09:13
Date of report	29/11/2016

Pre-test conditions

Ambient temperature	19.3°C
Ambient pressure	96.901 kPa
Relative humidity	35%

Test times

Time to ignition	not recorded
Time to flameout	s
End of test criterion	User entered
End of test time	900 s
(for calculations)	

Apparatus specifications

C-factor	0.04298
Duct diameter	0.114 m
O ₂ delay time	17 s
CO ₂ delay time	17 s
CO delay time	17 s
OD corr. factor	1.0055

Initial conditions

Baseline ambient oxygen	20.779%
Baseline oxygen	20.949%
Baseline carbon dioxide	0.0735%
Mass at sustained flaming	no ignition

Heat Release Results

THR (0-300)	0.22 MJ/m ²
THR (0-600)	0.53 MJ/m ²
THR (0-1200)	-
Fuel load	0.10 MJ/kg

Test results (between 0 and 900 s)

		Mean	Peak	at time (s)	
Total heat release	1.4 MJ/m ²	Heat release rate (kW/m ²)	1.18	7.66	749
Total oxygen consumed	1.5 g	Effective heat of comb. (MJ/kg)	0.29	53.42	877
Mass lost	32.6 g	Mass loss rate (g/s)	0.036	0.230	895
Average specific MLR	4.47 g/(s·m ²)	Specific extinction area (m ² /kg)	0.58	3269.41	601
Total smoke release	31.5 m ² /m ²	Carbon monoxide yield (kg/kg)	0.0082	19.9390	799
Total smoke production	0.3 m ²	Carbon dioxide yield (kg/kg)	0.12	208.65	799
MAHRE	1.6 kW/m ²				

Test averages

	between time 0 and... 1 min	2 min	3 min	4 min	5 min	6 min		0 s - 903 s	0 s - 903 s
Heat release rate (kW/m ²)	-0.49	-0.59	-0.31	-0.12	-0.02	0.01		1.19	1.19
Effective heat of comb. (MJ/kg)	-0.16	-0.16	-0.08	-0.03	-0.00	0.00		0.29	0.29
Mass loss rate (g/s)	0.028	0.034	0.037	0.041	0.043	0.044		0.036	0.036
Specific extinction area (m ² /kg)	-2.20	0.00	0.59	-0.91	0.19	-0.07		0.65	0.65
Carbon monoxide yield (kg/kg)	0.0017	0.0019	0.0032	0.0036	0.0038	0.0040		0.0083	0.0083
Carbon dioxide yield (kg/kg)	0.08	0.07	0.07	0.08	0.08	0.08		0.12	0.12

Smoke results

Total smoke release: whole test (0 s - 900 s) 31.5 m²/m²

Sample description 102816357MID-001 Terasun Mg Board
Material name/ID 102816357MID-001 Terasun Mg Board

Specimen information

E	13.1 MJ/kg	Specimen number	6	Conditioned?	Yes
Thickness	12 mm	Nominal duct flow rate	24 l/s	Temperature	23°C
Initial mass	123.5 g	Edge frame used?	Yes	RH	50%
Surface area	88.4 cm ²	Grid used?	No		
Heat flux	50 kW/m ²	Manufacturer			
Separation	25 mm	Sponsor			
Orientation	Horizontal				

Test

Standard used	ULC S135
Date of test	29/11/2016
Time of test	09:32
Date of report	29/11/2016

Pre-test conditions

Ambient temperature	20.9°C
Ambient pressure	96.976 kPa
Relative humidity	34%

Test times

Time to ignition	not recorded
Time to flameout	s
End of test criterion	User entered
End of test time	900 s
(for calculations)	

Apparatus specifications

C-factor	0.04298
Duct diameter	0.114 m
O2 delay time	17 s
CO2 delay time	17 s
CO delay time	17 s
OD corr. factor	1.0055

Initial conditions

Baseline ambient oxygen	20.767%
Baseline oxygen	20.949%
Baseline carbon dioxide	0.0741%
Mass at sustained flaming	no ignition

Heat Release Results

THR (0-300)	0.18 MJ/m ²
THR (0-600)	0.61 MJ/m ²
THR (0-1200)	-
Fuel load	0.08 MJ/kg

Test results (between 0 and 900 s)

		Mean	Peak	at time (s)	
Total heat release	1.2 MJ/m ²	Heat release rate (kW/m ²)	0.87	6.39	891
Total oxygen consumed	1.3 g	Effective heat of comb. (MJ/kg)	0.21	64.08	322
Mass lost	32.4 g	Mass loss rate (g/s)	0.036	0.279	233
Average specific MLR	4.37 g/(s·m ²)	Specific extinction area (m ² /kg)	-8.64	3315.56	321
Total smoke release	17.1 m ² /m ²	Carbon monoxide yield (kg/kg)	0.0064	3.5049	539
Total smoke production	0.2 m ²	Carbon dioxide yield (kg/kg)	0.13	59.50	539
MAHRE	1.4 kW/m ²				

Test averages

	between time 0 and... 1 min	2 min	3 min	4 min	5 min	6 min	0 s - 903 s	0 s - 903 s
Heat release rate (kW/m ²)	-0.58	-0.63	-0.78	-0.61	-0.37	-0.02	0.88	0.88
Effective heat of comb. (MJ/kg)	-0.16	-0.16	-0.17	-0.12	-0.07	-0.00	0.22	0.22
Mass loss rate (g/s)	0.031	0.035	0.039	0.044	0.045	0.045	0.036	0.036
Specific extinction area (m ² /kg)	-14.27	-12.30	-10.44	-8.87	-7.80	-8.24	-8.64	-8.64
Carbon monoxide yield (kg/kg)	0.0004	0.0010	0.0021	0.0023	0.0026	0.0029	0.0065	0.0065
Carbon dioxide yield (kg/kg)	0.09	0.09	0.09	0.09	0.10	0.10	0.13	0.13

Smoke results

Total smoke release: whole test (0 s - 900 s) 17.1 m²/m²

Heat flux 50 kW/m² Surface area 88.4 cm²
Orientation Horizontal Retainer frame used? Yes

Test averages

Test	t(ig) (s)	t(fo) (s)	t(end) (s)	HRR(peak) (kW/m ²)	tpeak (s)	THR (MJ/m ²)	HRR(60) (kW/m ²)	HRR(180) (kW/m ²)	HRR(300) (kW/m ²)
Mean	0	0	900	7.81	677.5	2.00	-0.14	0.27	0.73
1	0		900	13.15	725	4.96	0.70	1.58	2.73
2	0		900	6.59	126	1.12	0.02	1.20	1.64
3	0		900	7.60	857	2.26	0.72	0.95	1.24
4	0		900	5.50	717	1.01	-1.23	-1.01	-0.82
5	0		900	7.66	749	1.44	-0.49	-0.31	-0.02
6	0		900	6.39	891	1.18	-0.58	-0.78	-0.37

Test	Flux (kW/m ²)	t (mm)	Area (cm ²)	m(i) (g)	m(s) (g)	m(f) (g)	Δm (g)	Ave MLR (g/s·m ²)	EHC(av) (MJ/kg)
Mean		12		125.2	125.2	93.3	32.0	4.4	0.46
1	50	12	88.4	125.6	125.6	94.1	31.5	4.3	1.38
2	50	12	88.4	125.9	125.9	94.6	31.3	4.3	0.18
3	50	12	88.4	125.1	125.1	93.0	32.1	4.5	0.60
4	50	12	88.4	124.7	124.7	92.7	32.0	4.3	0.12
5	50	12	88.4	126.6	126.6	94.0	32.6	4.5	0.29
6	50	12	88.4	123.5	123.5	91.1	32.4	4.4	0.21

Test	THR(0-300) (MJ/m ²)	THR(0-600) (MJ/m ²)	THR(0-1200) (MJ/m ²)	SPR(av) (m ² /s)	SEA(av) (m ² /kg)	Fuel load (MJ/kg)	MARHE (kW/m ²)
Mean	0.40	1.02	-	0.0002	4.80	0.14	2.40
1	0.88	2.40	-	0.0007	18.58	0.35	5.51
2	0.56	0.92	-	0.0007	21.40	0.08	1.98
3	0.45	1.26	-	-0.0001	-3.28	0.16	2.84
4	0.12	0.43	-	0.0000	0.15	0.07	1.12
5	0.22	0.53	-	0.0000	0.58	0.10	1.60
6	0.18	0.61	-	-0.0003	-8.64	0.08	1.36



Test	Date	Specimen #	Line colour	Filename
1	29/11/2016	1		C:\CC5\Data\Intertek Shanghai\102816357\102816357MID-001 Terasun Mg Board 1.csv
2	29/11/2016	2		C:\CC5\Data\Intertek Shanghai\102816357\102816357MID-001 Terasun Mg Board 2.csv
3	29/11/2016	3		C:\CC5\Data\Intertek Shanghai\102816357\102816357MID-001 Terasun Mg Board 3.csv
4	29/11/2016	4		C:\CC5\Data\Intertek Shanghai\102816357\102816357MID-001 Terasun Mg Board 4.csv
5	29/11/2016	5		C:\CC5\Data\Intertek Shanghai\102816357\102816357MID-001 Terasun Mg Board 5.csv
6	29/11/2016	6		C:\CC5\Data\Intertek Shanghai\102816357\102816357MID-001 Terasun Mg Board 6.csv

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.



Observations for all of the samples:

All specimens visibly darkened but did not ignite.



Graphs




The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.



The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.



The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.



Summary of Total Smoke Production

	Total Smoke Production
Specimen #	m ²
1	0.7
2	0.7
3	0.2
4	0.3
5	0.3
6	0.2
Average	0.4

6 Conclusion

Intertek has conducted testing for Zhejiang Terasun Air Duct Co., Ltd., on Terasun Magnesium Board to evaluate heat and smoke release rates. Testing was conducted following the standard methods of ULC S135-04 Standard Test Method for the Determination of Combustibility Parameters of Building Materials Using an Oxygen Consumption Calorimeter (Cone Calorimeter) in accordance with the National Building Code of Canada for materials used in buildings that are required to be of noncombustible.

There are no pass/fail criteria for ULC S135-04.

With reference to the National Building Code of Canada, the material had an average total heat release of 2.00 MJ/m² (3 MJ/m² maximum allowable) and average total smoke extinction area of 0.4 m² (1.0 m² maximum allowable). It therefore **passed** the National Building Code of Canada for materials used in buildings that are required to be noncombustible.

The conclusions of this test report may be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

INTERTEK



Reported by:

Tolu Bamikunle
Lab Technician III, Verification Center



Reviewed by:

Bryan Bowman
Chemist, Verification Center

REVISION SUMMARY

DATE	SUMMARY
November 30, 2016	Original date of report
